

Routine Fuel Oil Storage Tank Evaluation – above ground tanks
Revised May 2006

Name _____
 Address _____
 Town _____ State _____ Zip _____
 Telephone () _____

Tank

Tank securely mounted in flood prone areas?	N/A	Yes	No
Any evidence of historic oil spills?		Yes	No
Tank checked for oil leaks?		Yes	No
Amount of oil in tank?		<hr/>	
Any water in tank?		Yes	No
If yes, how many inches?		<hr/>	
Tank gauge in good condition?		Yes	No
Tank at least 5 feet from burner or other sources of fire or flame?		Yes	No
Evidence of external corrosion?		Yes	No
Unused openings properly plugged?		Yes	No

Comments: _____

Fill Pipe

In good condition?		Yes	No
Fill cap in place & in good condition?		Yes	No
Fill positioned to avoid buildup of water and snow?		Yes	No
Fill properly identified?		Yes	No

Comments: _____

Vent Pipe

In good condition?		Yes	No
Vent cap in place & in good condition?		Yes	No
Vent free of obstructions?		Yes	No
Positioned to avoid buildup of water and snow?		Yes	No

Comments: _____

Oil lines

Working shutoff at tank?		Yes	No
All lines properly connected to tank and burner?		Yes	No
Outside exposed lines insulated?	N/A	Yes	No

Comments: _____

This tank is still acceptable for fuel delivery		Yes	No
---	--	-----	----

Comments: _____

Inspected by: _____ **Date:** _____